

Quotation

To

Company : Siemens AG
City / Country : Duisburg / Germany
Name : Stoverink Simon
Dept :
Tel :
Fax :
E-mail :

Name : N. HOST
Dept : Sales Dept.
Tel : +33 (0)3 69 20 51 50
Fax : +33 (0)3 88 67 60 75
E-mail : nhost@flender-graff.com
Page(s) : 19
Copy :
Date : 16.03.2015

Y/ref : Khursaniyah Al Fadhili - D43-K-1801 -
O/ref : D41104 quotation number 3

In response to your inquiry referenced above, we are pleased to confirm our quotation as follows :

ITEM A 1 : Flender Graffenstaden (FG) High Speed increaser, model **TX50/4C**

- *Rating conditions :* Rated power at **6800 kW**
Driven by a electric motor at **1800.0 rpm** (specified : 1800.0 rpm)
Driving a centrifugal compressor at **7309.1 rpm** (specified : 7285.0 rpm)
Service factor **1.45** according to **API613/03** (required : > 1.4)
- *Technical description :* Double helical
Manufacturing according to API standard
Flange on LS shaft end
Flange on HS shaft end
Estimated Weight : 4000 kg
- *Bearings description :* 2 cylindrical bearings on LS shaft
2 offset bearings on HS shaft
1 double acting tilting pad thrust bearing on low speed shaft non driven end
- *Mechanical running test :* Full speed, no load test during 4 hours according to the API 613 5th Edition standard.
- *Lubrication conditions :* 164 l/min of Oil ISO VG 46 at 60°C and 2.5 bar at inlet (calculated values only)
- *Miscellaneous:* Efficiency at full load : 99.03 %
Power losses at full load : 66 kW (calculated value only)
Anticipated Sound Pressure Level: 82.0 ± 2dB(A) at 1 meter

Base price : **117 900 EUR** each gear box
Delivery time : **36 weeks** after the FG acknowledgement of the order
Quantity : **8 gearboxes**

Comments :

- Coupling data taken into account on HS Shaft:
 - o Weight: 26.6 kg
 - o Center of gravity position from shaft end: 30.9 mm
 - o Inertia: 0.266 kgm²
- Coupling data taken into account on LS Shaft:
 - o Weight: 87.5 kg
 - o Center of gravity position from shaft end: 40.9 mm
 - o Inertia: 0.875 kgm²

Including :

- Customer witness of test
- After test disassembly and inspection
- Noise level test report
- Lateral analysis undamped
- Documentation : downloadable electronic file in english

Instrumentation (see the complete package on additional technical data sheet):

- *Temperature package*
12 RTD's PT100 Duplex 3 wires from Thermo Electric Company Inc.
(2 per bearing and thrust bearing side) not wired with terminal heads..... Price included
- *Bently Nevada vibration package*
8 radial (4 per shaft) & 2 axial (on LS shaft) vibration probes, 2 accelerometers (1 per shaft), 2 keyphasors (1 per shaft) not wired Price included

Spare parts (Prices are net valid only if spares are ordered together with the gearbox):

- *Commissioning Spares*
2 RTD's, 2 BN vibration probes, 2 BN accelerometers 7 900 EUR Lot Net
- *2 Years Normal Operation Spares*
2 set of bearings with RTD's, 1 set of oil seals 48 420 EUR Lot Net
- *Strategic Spare Parts*
One complete set of rotating elements consisting of one pinion and one gear.
Tested if ordered together with the main gearbox according to API613/03
Full Speed, No Load, with Test Report..... 51 500 EUR Lot Net
- *Container for horizontal spare rotors storage painted according FG standard*..... 17 100 EUR Lot Net

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. 41104 Item No. A
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision 1 Date 06.03.2015 By HNI

1	Applicable To: ☒ Proposal ☐ Purchase ☐ As Built	☐ US Standards (1.7) ☒ ISO Standards (1.7)
2	For <u>Siemens AG Duisburg</u>	Manufacturer <u>FLENDER-GRAFFENSTADEN</u>
3	Site <u>Khursanlyah Al Fadhill</u>	Model No. <u>TX50/4C</u>
4	Unit <u>STC-SV 08-4-A</u>	Serial No. _____
5	Service <u>EM/CC</u>	Driver type <u>electric motor</u>
6	No. required <u>9</u>	Driven equipment <u>centrifugal compressor</u>
7		
8	NOTE: Numbers within () refer to applicable API standard 613 paragraphs	
9	☐ Information To be completed by purchaser ☐ Information to be completed by manufacturer	
10	○ UNITS OF MEASUREMENT	■ BASIC GEAR DATA
11	☐ US Customary units	☒ Single stage ☐ Single helical ☐ Double stage ☒ Double helical ☐ Epicyclic ☐ horizontal offset
12	☒ SI units	
13	○ RATING REQUIREMENTS	
14	Driven equip. (2.1.4): Norm. _____ Max _____ kW	
15	Driver: Rated _____ Max _____ kW	
16	Normal transmitted power (2.2.2) _____ kW	
17	Gear unit rated power (2.2.1) <u>6800</u> kW	
18	Torque @ max cont speed _____ Nm	
19	Max torque (2.2.1) _____ Nm @ _____ rpm	
20	☐ Reducer ☒ Increaser	
21	Rated speed (2.1.5):	Mechanical rating (1.5.16) <u>9520</u> kW @ <u>1800 / 7309,1</u> rpm
22	Input <u>1800</u> rpm ☐ Specified ☒ Nominal	Gear service factor (2.2.3.1) <u>1,44</u> API 613/2003 5 TH (actual)
23	Output <u>7285</u> rpm ☐ Specified ☒ Nominal	Full load gear unit power loss <u>66</u> kW
24	Allow var in gear ratio (2.1.5) (+) (-) _____ %	Gear Unit Mechanical efficiency <u>99,03</u> %
25	Max continuous speed (1.5) <u>1800 / 7285</u> rpm	Rating speed Pinion <u>7.309,1</u> Gear <u>1.800,0</u> rpm
26	Trip speed (1.5) (2.1.7) <u>1980 / 8013,5</u> rpm	Hardness used for
27	Gear service factor (2.2.3.1) <u>1,4</u> API 613/2003 5 TH (min)	Rating, (HB or Rc) Pinion <u>58 HRC</u> Gear <u>58 HRC</u>
28	Hardness (2.2.3.2) Pinion _____ Gear _____	Tooth pitting Index, "K" (2.2.4.1) (2.2.4.2)
29	Shaft assembly designation (2.1.18) <u>L/R</u>	Allowable <u>2,17</u> Actual <u>2,10</u> MPa
30	HS shaft rot fac'g cpl'g (2.1.20.2) ☒ CW ☐ CCW	Material index number (Fig 3, Table 4) <u>3,03</u> MPa
31	LS shaft rot fac'g cpl'g (2.1.20.2) ☒ CW ☐ CCW	Bending stress number, "S _t " (2.2.5.1) (2.2.5.2)
32	External loads (2.1.16) _____	Pinion: Allowable <u>265,4</u> Actual <u>256,0</u> MPa
33	Other operating conditions (2.2.2) (2.6.1.3) _____	Gear: Allowable <u>265,4</u> Actual <u>246,0</u> MPa
34		Pitch line velocity <u>77,1</u> m/s
35	○ INSTALLATION DATA (2.1.14)	Anticipated SPL (2.1.6) <u>82</u> dB(A) @ <u>1</u> m
36	☐ Indoor ☐ Heated ☐ Under roof	WR ² referred to LS shaft <u>126,12</u> kgm ²
37	☒ Outdoor ☐ Unheated ☐ Partial slides	Breakaway torque <u>412</u> Nm @ LS Shaft
38	☐ Grade ☐ Mezzanine ☒ ONSHORE	Pinion teeth hardness range <u>58 - 63 HRC</u>
39	☐ Winterization required ☐ Tropicalization required	Pinion teeth hardening method <u>CARBURIZED</u>
40	Electrical area (2.1.10) Class _____ Grp _____ Div _____	☐ HS shaft separate hardness range _____
41	Electrical area (2.1.10) Zone <u>2</u> Grp <u>IIA</u> Temp <u>T1</u> °C	Gear teeth (rim) hardness range <u>58 - 63 HRC</u>
42	Max allow SPL (2.1.6) _____ dB(A) @ _____ m	Gear teeth hardening method <u>CARBURIZED</u>
43	Elevation _____ m Barometer _____ kPa abs	Gear hub:
44	Range of ambient temperatures:	☒ Forged cylinder ☐ Forged & Copped ☐ Fabricated
45	Dry bulb _____ °C Wet bulb _____ °C	Gear to Shaft fit method (2.5.3.2)
46	Normal _____ °C _____ °C	☐ Integral ☐ Keyed interference ☒ Keyless interference
47	Maximum <u>82</u> °C _____ °C	Rim attachment (2.5.3.2) <u>FORGED GEAR WHEEL</u>
48	Minimum <u>0</u> °C _____ °C	LS shaft hardness range <u>HB 230 - 274</u>
49	Unusual conditions ☐ Dust ☐ Fumes	Journal static weight loads (2.6.6.3)
50	☐	Pinion <u>128</u> / <u>42</u> kg Gear <u>842</u> / <u>707</u> kg
		Total gear unit assembled weight <u>4000</u> kg
		NOTES: _____

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. 41104 Item No. A
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision 1 Date 06.03.2015 By HNI

■ GEAR DATA				○ COUPLINGS AND GUARDS		
	Pinion	Gear		Pinion	Gear	
Number of teeth	33	134	Coupling furnished by (3.2.1)	Compr. Supplier	Compr. Supplier	
Gear ratio	4,06		Mount coupling halves (3.2.2)	Compr. Supplier	Compr. Supplier	
Tangential load, "Wt" (2.2.4.2)	88.155	N	Cplg. guard adapter by (3.2.3)	Gear Supplier	Gear Supplier	
AGMA Geometry factor "J"	0,55	0,57	Cplg. guard furnished by (3.2.3)	Compr. Supplier	Compr. Supplier	
Pitch diameter	201,56	818,44	Coupling vendor (3.2.3)			
Outside diameter	214,10	827,60	Vendor's model number (3.2.3)			
Root diameter	187,25	800,74	Coupling weight on shaft, kg	26,6	87,5	
Center groove diameter	177,00	790,00	CG inboard / outboard of shaft end	Outboard	Outboard	
Normal pressure angle	20,00	deg	Hub drill template provided	☐	☐	
Normal diametral pitch	4,62	in ⁻¹	■ SHAFT END DETAIL (2.5.4.2)			
Helix angle	25,00	deg	Shaft end detail specified by: ☒ Purchaser ☐ Gear vendor			
Center distance	510,00	mm	(Integral unless otherwise specified)			
Backlash min	0,34	mm	Shaft end detail if 'otherwise' specified:			
Net face width, "Fw"	260,00	mm	Pinion Gear			
Pinion L/D	1,71		Tapered / Keyless ☐ ☐ ☐ ☐			
Face overlap ratio	6,36		Tapered / 1-Key ☐ ☐ ☐ ☐			
Transverse contact ratio	1,45		Tapered / 2-Keys ☐ ☐ ☐ ☐			
AGMA 6011 service factor	2,64		Cylindrical / 1-Key ☐ ☐ ☐ ☐			
Rating based on ANSI/AGMA 6011 with SF=1.0			Cylindrical / 2-Keys ☐ ☐ ☐ ☐			
Durability Power	21442	kW	Other <u>Flanged</u> ☒ ☐ ☐ ☐			
Strength Power	17946	kW	Shaft diameter <u>120,0</u> <u>190,0</u> mm			
Tooth Surface Finish, Ra	0,4	µm	(If integral flange use diameter immediately adjacent to flange)			
Tooth Generation Process	Hobbling		■ RADIAL BEARINGS			
Tooth Finishing Process	Grinding		Pinion Gear			
Lead modification (2.2.4.6) ☒ Not Req'd ☐ Req'd			Type <u>OFFSET / OFFSET</u> <u>CYL. / CYL.</u>			
Calculated Total Lead Mismatch		µm	Diameter <u>130 / 130</u> <u>200 / 200</u> mm			
■ SCUFFING DATA (2.2.6)			Length <u>130 / 130</u> <u>100 / 100</u> mm			
Scuffing Data per ANSI/AGMA 926-A03			Journal velocity <u>49,8 / 49,8</u> <u>18,8 / 18,8</u> m/s			
Scuffing Risk (2.2.6) <u><=5% (Low)</u>	Calculation Method	<u>AGMA925</u>	Loading <u>2,78 / 2,81</u> <u>2,87 / 2,71</u> N/mm²			
Composite surface roughness, σx	<u>0,57</u>	µm	Clearance (min-max)			
Specific film thickness, EHL λmin	<u>3,31</u>	µm	Span <u>550</u> <u>550</u> mm			
Tooth temperature, θm	<u>82</u>	°C	Power loss each bearing <u>13,8 / 13,8</u> <u>3,0 / 3,0</u> kW			
Maximum contact temperature, θBmax	<u>101</u>	°C	Oil flow each bearing <u>42,0 / 42,0</u> <u>10,0 / 10,0</u> l/min			
■ MATERIALS			■ THRUST BEARINGS			
Gear casing	<u>Steel</u>	Oil seals	<u>aluminum</u>	Location		
Pinion(s)	<u>18CrNiMo7-6</u>			Manufacturer		
Gear rim(s)	<u>18CrNiMo7-6</u>			<u>FLENDER</u> <u>FLENDER</u>		
HS Shaft	<u>Integral</u>	LS Shaft	<u>42CrMo4</u>	Type		
Radial bearings	<u>Babbitt</u>	Backing	<u>Steel</u>	<u>NO</u> <u>COMB.TAP.LANDS</u>		
Thrust bearing(s)	<u>Babbitt</u>	Backing	<u>Steel</u>	Size		
○ SHAFT END DETAIL			<u>BPK LEG 6"</u>			
☒ Gear shaft end for coupling integral flange (2.5.4.2)	Area					
☒ Pinion shaft end for coupling integral flange (2.5.4.2)	<u>11615</u> mm²					
☒ Other : <u>WITHOUT BOLTS</u>	Loading					
	<u>1,14</u> MPa					
	Rating					
	<u>1,50</u> MPa					
	Int. thrust load					
	<u>4.050</u> <u>9.200</u> N					
	Ext. thrust load					
	<u>0,0</u> <u>6,0</u> kW					
	Power loss each					
	<u>0,0</u> <u>20,0</u> l/min					
	Oil flow each bearing					
	NOTES :					

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

○ LUBRICATION REQUIREMENTS ☐ Oil system furnished by (2.8.3) _____ ☐ Other _____ ☐ Gear vendor _____ ☐ Oil visc. _____ cp @ 40°C _____ cp @ 100°C (2.8.6) ☐ ISO Grade _____ Load stage (2.2.6) 5,0 ■ MESH Mech and windage power loss 26,4 kW Oil flow, mesh 40,0 l/min ■ LUBRICATION REQUIREMENTS Min. startup oil temperature 20,0 °C Normal oil inlet temperature 60,0 °C Maximum oil inlet temperature 65,0 °C Unit oil flow (total) 164,0 l/min Unit oil pressure 2,5 bar ☐ Oil visc. _____ cp @ 40°C _____ cp @ 100°C (2.8.6) ☐ ISO Grade 46 Load stage (2.2.6) 5,0 ■ PIPING CONNECTIONS <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Service</th> <th>No.</th> <th>Size</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>Lube oil inlet</td> <td>1</td> <td>2 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Lube oil outlet</td> <td>1</td> <td>6 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Casing drain *</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vent</td> <td>1</td> <td>1,5 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Casing purge</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> * Casing drain is 'dead bottom' housing drain, not lube oil outlet ○ MOUNTING PLATES ☐ Gear furnished with (3.3.1.1) ☐ Baseplate ☐ Soleplate ☐ Subplate(s) (3.3.2.10) ☐ Mounting plates(s) furnished by (3.3.1.1) _____ ☐ Baseplate leveling (3.3.2.3) _____ ☐ Baseplate with leveling pads (3.3.2.3) ☐ Baseplate suitable for column mounting (3.3.2.4) ☐ Vendor review of purchaser's foundation dwgs. (2.1.13) ☐ Grout type (3.3.1.2.4) _____ ○ CONTRACT DATA ☐ Test data prior to shipment _____ ☒ Progress report (5.3.3) _____ ☐ Vendor signoff of inspector checklist (4.1.1.3) ☒ Information retained for 20 years (4.2.1.1) (4.2.2.6.1) ☐ Technical manual (5.3.5.4) ☒ PAINTING (4.4.3.1) ☒ Flender standard RAL5015 (blue) ☒ Painting housing interior not allowed (2.3.1.14) ○ SHIPMENT <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Contract unit</th> <th>Spares</th> </tr> </thead> <tbody> <tr> <td>Export boxing</td> <td>☐</td> <td>☐</td> </tr> <tr> <td>Domestic boxing</td> <td>☐</td> <td>☐</td> </tr> <tr> <td>Outdoor storage over 6 mos.</td> <td>☐</td> <td>3 years indoor ☐ (4.4.3.9)</td> </tr> </tbody> </table>	Service	No.	Size	Type	Lube oil inlet	1	2 in.	ANSI 150 LBS	Lube oil outlet	1	6 in.	ANSI 150 LBS	Casing drain *				Vent	1	1,5 in.	ANSI 150 LBS	Casing purge					Contract unit	Spares	Export boxing	☐	☐	Domestic boxing	☐	☐	Outdoor storage over 6 mos.	☐	3 years indoor ☐ (4.4.3.9)	Job No. 41104 Item No. A P.O. No. _____ Date _____ Requisition No. _____ Inquiry No. _____ Revision 1 Date 06.03.2015 By HNI ○ ADDITIONAL REQUIREMENTS ○ VIBRATION DETECTORS RADIAL (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ Total No. 8 ☒ X-Y probes pinion bearings ☒ Coupling end ☒ Blind end ☒ X-Y probes gear bearings ☒ Coupling end ☒ Blind end ☐ Other _____ AXIAL (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ Total No. 2 ☐ Dual probes at each thrust bearing ☐ Single probe any shaft without thrust bearing ☐ Other _____ ONE EVENT PER REVOLUTION PROBE (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA Total No. 2 ☒ One on input shaft ☒ One on output shaft ☐ Other _____ ACCELEROMETER (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ No. required 2 ☒ Pinion coupling end ☒ Gear coupling end ☐ Other _____ ○ TEMPERATURE DETECTORS ☐ Dial type thermometers (3.4.2.7) _____ ☒ Type brg. temp. sensors (3.4.2.7) (2.7.1.3) PT100 ☐ RTD ☐ Thermocouple ☐ Simplex ☒ Duplex Calibration Yes ☒ HSLS bearings no. sensors each 2 / 2 ☒ Thrust number of sensing elements each face 2 ○ OTHER VIBRATION AND TEMPERATURE <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>(3.4.2.5) (3.4.2.6)</th> <th>Other</th> <th>Gear vendor</th> </tr> </thead> <tbody> <tr> <td>Oscillator demodulator supplied by</td> <td>☐</td> <td>☒</td> </tr> <tr> <td>Vibration monitor supplied by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Vibration shutdown delay time _____ seconds</td> <td></td> <td></td> </tr> <tr> <td>Temperature monitor supplied by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Oscillator demodulator J-box by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Temp. sensor termination J-box by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>J-box type _____ Mount _____</td> <td></td> <td></td> </tr> </tbody> </table> ○ MISCELLANEOUS ☒ Undamped critical analysis report (2.6.2.1) ☐ w/ dampd rtr resps analys rpt (2.6.2.4.3) (2.6.2.6) Torsional analysis by (2.6.5.2) ☐ Gear vendor ☒ Other ☐ Spare set of gear rotors (4.3.2.4) ☐ Gear case furnished with inlet purge connection (2.4.3) ☐ Orientation of oil inlet & drain conns. (2.4.6) _____ ☒ Filter breather location (2.3.1.12) Prov. on upper casing ☐ Torsional device provisions (2.5.4.5) _____ ☐ Rotor vertical storage provisions (2.5.4.8) _____ ☐ Rotor vertical storage fixture(s) (3.6.2) _____ ☐ Vendor service rep. on site (2.1.13)	(3.4.2.5) (3.4.2.6)	Other	Gear vendor	Oscillator demodulator supplied by	☐	☒	Vibration monitor supplied by	☒	☐	Vibration shutdown delay time _____ seconds			Temperature monitor supplied by	☒	☐	Oscillator demodulator J-box by	☒	☐	Temp. sensor termination J-box by	☒	☐	J-box type _____ Mount _____		
Service	No.	Size	Type																																																										
Lube oil inlet	1	2 in.	ANSI 150 LBS																																																										
Lube oil outlet	1	6 in.	ANSI 150 LBS																																																										
Casing drain *																																																													
Vent	1	1,5 in.	ANSI 150 LBS																																																										
Casing purge																																																													
	Contract unit	Spares																																																											
Export boxing	☐	☐																																																											
Domestic boxing	☐	☐																																																											
Outdoor storage over 6 mos.	☐	3 years indoor ☐ (4.4.3.9)																																																											
(3.4.2.5) (3.4.2.6)	Other	Gear vendor																																																											
Oscillator demodulator supplied by	☐	☒																																																											
Vibration monitor supplied by	☒	☐																																																											
Vibration shutdown delay time _____ seconds																																																													
Temperature monitor supplied by	☒	☐																																																											
Oscillator demodulator J-box by	☒	☐																																																											
Temp. sensor termination J-box by	☒	☐																																																											
J-box type _____ Mount _____																																																													

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. 41104 Item No. A
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision 1 Date 06.03.2015 By HNI

O INSPECTIONS AND TESTS (4.1)				
☐ Advance notice of witness testing required (4.1.3) Number calendar days _____				
	Req'd	Witness	Observe	Test Log
6	Shop Inspection (4.1.1)	☐	☐	☐
7	Cleanliness Inspection (4.2.3.1)	☐	☐	☐
8	Hardness Verification (4.2.3.3)	☒	☐	☒
9	Dismantle/reassembly (4.3.2.3.1)	☒	☐	☐
10	Contact Check (2.5.2.2)	☒	☐	☐
11	Contact Check Tape Lift (2.5.2.2)	☒	☐	☒
12	Gear accuracy check (2.5.2.1)	☒	☐	☐
13	Double helical axial stability (2.5.2.3)	☒	☐	☒
14	Special testing Integral forged gears (2.5.3.3)			
15	(testing per mutual agreement)	☐	☐	☐
16	Residual unbalance check (2.6.6.2)	☒	☐	☒
17	Mechanical Run Test (Main) (4.3.2)	☒	☐	☒
18	Mechanical Run Test (Spare) (4.3.2.4)	☐	☐	☐
19	Addtl. Mechanical Tests (4.3.2.2.16)	☐	☐	☐
20	Part or Full Load And Full Speed			
21	Test (4.3.3.1)	☐	☐	☐
22	Full torque, reduced speed (4.3.3.2)	☐	☐	☐
23	Full Torque Static Test (4.3.3.3)	☐	☐	☐
24	Back-To-Back Locked Torque			
25	Test (4.3.3.4)	☐	☐	☐
26	Sound Level Test (4.3.3.5)	☒	☐	☒
27	Additional gear tooth test (4.2.2.8)	☐	☐	☐
28	Use shop Lube System	☒	☐	☐
29	Use Job lube system	☐	☐	☐
30	Use shop Vibration Probes, Etc.	☐	☐	☐
31	Use Job Vibration Probes, Etc.	☒	☐	☐
32	Final Assembly, Maintenance &			
33	Running Clearance (4.2.1.1.e)	☒	☐	☒
34	Oil System Cleanliness (4.2.3.2)	☐	☐	☐
35	Oil System-Casing Joint			
36	Tightness (4.3.2.1.4)	☐	☐	☐
37	Warning And Protection			
38	Devices (4.3.2.1.5)	☐	☐	☐
39	Seismic Vibration Data (4.3.2.2.3)	☐	☐	☐
40	Vibration, Phase Plots (4.3.2.2.12)	☒	☐	☒
41	Oil Inlet Range test (4.3.2.2.13)	☐	☐	☐
42	Tape recorded Vibration Data	☒	☐	☒
43	(4.3.2.2.14) (4.3.2.2.15)	☐	Purchaser copy	
44	NON-DESTRUCTIVE TESTING (4.2.1.2) (4.2.2.1)			
45		Surface	Sub surface	Log
46	☐ Casing	☐	☐	☐
47	☒ Rot. Elmts.	☒	☒	☒
48	☒ Bearings	☒	☒	☒
49	☐ Other :	☐	☐	☐
50	(Specify)			


NOTES : _____

During start-up, gears can exhibit a transient spike reading of vibration levels that will exceed shutdown settings. Therefore a trip multiplier is recommended in the control system.



Mechanical running test duration 4 hours including

- Shaft vibration record using Job vibration probes if ordered
- Bearings temperature records
- Casing vibration measurement
- Sound level pressure measurement
- Power losses measurement at oil outlet
- Performed with oil ISO VG 32

Oil flow requirement and power losses are calculated values only, add normal safety margins for sizing heat exchangers.



Customer : Siemens AG Duisburg
Destination : Khursariyah Al Fadhilli
Purchaser order :
F-G job number : D 41104A1 OL:
Type and serial N° : TX50/4C
Power rating : 6800 kW
Service factor : AP16:3003 >=1,4
Input speed : 1800 rpm
Output speed : 7309,1 rpm
Speed ratio : 4,06
Weight HSS : 143,5 kg
Weight pos. from teeth middle HSS : 63,4 mm
Inertia HSS : 0,585 Kg.m²
Stiffness HSS : 5,916 MN/mrd
Bearing type 1 : Offset 130 x 130
Bearing type 2 : Offset 130 x 130
Add. weight on brg. side 1 : 26,6 kg
Weight LSS : 156,2 kg
Weight pos. from teeth middle LSS : 10,5 mm
Inertia LSS : 116,473 Kg.m²
Stiffness LSS : 39,014 MN/mrd
Bearing type 4 : Cylindrical 200 x 100
Bearing type 3 : Cylindrical 200 x 100
Add. weight on brg. side 4 : 87,5 kg



ADDITIONAL TECHNICAL DATASHEET				Job No. <u>41104</u> Item No. <u>A</u>																																				
				P.O. No. _____ Date _____																																				
				Requisition No. _____																																				
				Inquiry No. _____																																				
				Revision <u>1</u> Date <u>06.03.2016</u> By <u>HNI</u>																																				
☒ ADDITIONAL GEAR DATA			☐ TURNING GEAR (Dimensioning is preliminary !)																																					
Efficiency			Calculation results																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Percent of rated power</th> <th style="width: 50%;">Efficiency</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">100%</td> <td style="text-align: center;">99,03</td> </tr> <tr> <td style="text-align: center;">75%</td> <td style="text-align: center;">98,92</td> </tr> <tr> <td style="text-align: center;">50%</td> <td style="text-align: center;">98,79</td> </tr> <tr> <td style="text-align: center;">25%</td> <td style="text-align: center;">98,08</td> </tr> <tr> <td style="text-align: center;">10%</td> <td style="text-align: center;">90,80</td> </tr> </tbody> </table>			Percent of rated power	Efficiency	100%	99,03	75%	98,92	50%	98,79	25%	98,08	10%	90,80	Required turning speed _____ rpm Actual turning speed _____ rpm Required breakaway torque _____ Nm Actual breakaway torque _____ Nm Actual maximum torque _____ Nm Actual acceleration time _____ s																									
Percent of rated power	Efficiency																																							
100%	99,03																																							
75%	98,92																																							
50%	98,79																																							
25%	98,08																																							
10%	90,80																																							
Losses			Motor																																					
Power loss at no load _____ kW Heat rejection _____ kcal/h			Supplier _____ Power _____ kW Voltage _____ V Frequency _____ Hz Speed _____ rpm Electric standard _____																																					
☐ PUMP DETAILS (Dimensioning is preliminary !)																																								
Design : _____ Speed : _____ rpm Oil flow : _____ l/min Oil pressure : _____ bar NPSH : _____ m Safety valve : _____ Driving method : _____ Material : _____ Flanges : _____ Testing : _____ Furniture of ATEX certificate : _____			Turning gear Type _____ Ratio _____ Clutch Type _____ Max. allowable torque _____ Nm Miscellaneous Starting device _____ Switch details _____																																					
☒ INSTRUMENTATION PACKAGE																																								
Thermometer			Thermoelements																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="width: 33%;">Bearing</th> <th style="width: 33%;">Thrust bearing</th> <th style="width: 33%;">Oil inlet/outlet</th> </tr> </thead> <tbody> <tr> <td>Qty</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Type</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				Bearing	Thrust bearing	Oil inlet/outlet	Qty				Type				<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="width: 33%;">Bearing</th> <th style="width: 33%;">Thrust bearing</th> <th style="width: 33%;">Oil inlet/outlet</th> </tr> </thead> <tbody> <tr> <td>Type</td> <td>DUPLEX 2x3F</td> <td>DUPLEX 2x3F</td> <td></td> </tr> <tr> <td>Classification</td> <td>IEC60751</td> <td>IEC60751</td> <td></td> </tr> <tr> <td>Removable from the outside</td> <td>NO</td> <td>NO</td> <td></td> </tr> <tr> <td>ATEX</td> <td>ATEX Exia</td> <td>ATEX Exia</td> <td></td> </tr> </tbody> </table>				Bearing	Thrust bearing	Oil inlet/outlet	Type	DUPLEX 2x3F	DUPLEX 2x3F		Classification	IEC60751	IEC60751		Removable from the outside	NO	NO		ATEX	ATEX Exia	ATEX Exia				
	Bearing	Thrust bearing	Oil inlet/outlet																																					
Qty																																								
Type																																								
	Bearing	Thrust bearing	Oil inlet/outlet																																					
Type	DUPLEX 2x3F	DUPLEX 2x3F																																						
Classification	IEC60751	IEC60751																																						
Removable from the outside	NO	NO																																						
ATEX	ATEX Exia	ATEX Exia																																						
Shaft vibrations																																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="width: 25%;">Radial</th> <th style="width: 25%;">Axial</th> <th style="width: 25%;">Keyphasor</th> <th style="width: 25%;">Accelerometer</th> </tr> </thead> <tbody> <tr> <td>Type</td> <td>B N. 3300 XL 8mm Sys 9M</td> <td>HS No LS BENTLY NEVADA 3300 XL 8mm Sys 9M</td> <td>B N. 3300 XL 8mm Sys 9M</td> <td>ACCELEROMETER BENTLY</td> </tr> <tr> <td>Probe</td> <td>Yes</td> <td>HS No LS Yes</td> <td>Yes</td> <td></td> </tr> <tr> <td>Proximitor</td> <td>Yes</td> <td>HS No LS Yes</td> <td>Yes</td> <td></td> </tr> <tr> <td>Probe holder</td> <td>Yes</td> <td>HS No LS Yes</td> <td>Yes</td> <td></td> </tr> <tr> <td>Connection head</td> <td>Yes</td> <td>HS No LS Yes</td> <td>Yes</td> <td></td> </tr> <tr> <td>mounting kit</td> <td></td> <td></td> <td></td> <td>Yes</td> </tr> </tbody> </table>							Radial	Axial	Keyphasor	Accelerometer	Type	B N. 3300 XL 8mm Sys 9M	HS No LS BENTLY NEVADA 3300 XL 8mm Sys 9M	B N. 3300 XL 8mm Sys 9M	ACCELEROMETER BENTLY	Probe	Yes	HS No LS Yes	Yes		Proximitor	Yes	HS No LS Yes	Yes		Probe holder	Yes	HS No LS Yes	Yes		Connection head	Yes	HS No LS Yes	Yes		mounting kit				Yes
	Radial	Axial	Keyphasor	Accelerometer																																				
Type	B N. 3300 XL 8mm Sys 9M	HS No LS BENTLY NEVADA 3300 XL 8mm Sys 9M	B N. 3300 XL 8mm Sys 9M	ACCELEROMETER BENTLY																																				
Probe	Yes	HS No LS Yes	Yes																																					
Proximitor	Yes	HS No LS Yes	Yes																																					
Probe holder	Yes	HS No LS Yes	Yes																																					
Connection head	Yes	HS No LS Yes	Yes																																					
mounting kit				Yes																																				
Junction box(es)			Miscellaneous																																					
Qty <u>0</u> Manufacturer _____ Material _____ ATEX <u>None</u>			Identification ☒ wire ☒ conduit ☐ junction box Conduit type _____ Transmitter type _____ Qty _____ Terminal block type _____ Qty _____																																					

FLENDER GRAFFENSTADEN

FLENDER-GRAFFENSTADEN S.A., FRANCE
BP 84, F-67402 ILLKIRCH-CEDEX
1, rue du Vieux Moulin
F-67400 ILLKIRCH-GRAFFENSTADEN

Y/ref : Khursaniyah Al Fadhili - D43-K-3801 -
O/ref : D41104 quotation number 3

ITEM B 1 : Flender Graffenstaden (FG) High Speed increaser, model **TX40/5C**

- *Rating conditions :* Rated power at **1620 kW**
Driven by a electric motor at **1800.0 rpm** (specified : 1800.0 rpm)
Driving a centrifugal compressor at **10737.9 rpm** (specified : 10736.0 rpm)
Service factor **1.47** according to **API613/03** (required : > 1.4)
- *Technical description :* Double helical
Manufacturing according to API standard
Flange on LS shaft end
Flange on HS shaft end
Estimated Weight : 1900 kg
- *Bearings description :* 2 cylindrical bearings on LS shaft
2 tilting pads bearings on HS shaft
1 double acting tilting pad thrust bearing on low speed shaft non driven end
- *Mechanical running test :* Full speed, no load test during 4 hours according to the API 613 5th Edition standard.
- *Lubrication conditions :* 64 l/min of Oil ISO VG 46 at 60°C and 2.5 bar at inlet (calculated values only)
- *Miscellaneous:* Efficiency at full load : 98.70 %
Power losses at full load : 21 kW (calculated value only)
Anticipated Sound Pressure Level: 82.0 ± 2dB(A) at 1 meter

Base price : **103 850 EUR** each gear box

Delivery time : **36 weeks** after the FG acknowledgement of the order

Quantity : **1 gearbox**

Comments :

- Coupling data taken into account on HS Shaft:
 - o Weight: 10.4 kg
 - o Center of gravity position from shaft end: 28.2 mm
 - o Inertia: 0.104 kgm²
- Coupling data taken into account on LS Shaft:
 - o Weight: 26.4 kg
 - o Center of gravity position from shaft end: 30.9 mm
 - o Inertia: 0.264 kgm²

Including :

- Customer witness of test
- After test disassembly and inspection
- Noise level test report
- Lateral analysis undamped
- Documentation : downloadable electronic file in English

Instrumentation (see the complete package on additional technical data sheet):

- *Temperature package*
12 RTD's PT100 Duplex 3 wires from Thermo Electric Company Inc.
(2 per bearing and thrust bearing side) not wired with terminal heads..... Price included
- *Bently Nevada vibration package*
8 radial (4 per shaft) & 2 axial (on LS shaft) vibration probes, 2 accelerometers (1 per shaft), 2 keyphasors (1 per shaft) not wired Price included

Spare parts (Prices are net valid only if spares are ordered together with the gearbox):

- *Commissioning Spares*
2 RTD's, 2 BN vibration probes, 2 BN accelerometers 7 900 EUR Lot Net
- *2 Years Normal Operation Spares*
1 set of bearings with RTD's, 1 set of oil seals 26 010 EUR Lot Net
- *Strategic Spare Parts*
One complete set of rotating elements consisting of one pinion and one gear.
Tested if ordered together with the main gearbox according to API613/03
Full Speed, No Load, with Test Report..... 37 100 EUR Lot Net
- *Container for horizontal spare rotors storage painted according FG standard*..... 15 850 EUR Lot Net

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. 41104 Item No. B
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision 1 Date 06.03.2015 By HNI

1	Applicable To: ☒ Proposal ☐ Purchase ☐ As Built	☐ US Standards (1.7) ☒ ISO Standards (1.7)
2	For <u>Siemens AG Duisburg</u>	Manufacturer <u>FLENDER-GRAFFENSTADEN</u>
3	Site <u>Khursaniyah Al Fadhili</u>	Model No. <u>TX40/5C</u>
4	Unit <u>STC-SV 06-3-A</u>	Serial No. _____
5	Service <u>EMCC</u>	Driver type <u>electric motor</u>
6	No. required <u>1</u>	Driven equipment <u>centrifugal compressor</u>
7		
8	NOTE: Numbers within () refer to applicable API standard 613 paragraphs	
9	☐ Information To be completed by purchaser	☐ Information to be completed by manufacturer
10	☐ UNITS OF MEASUREMENT	☒ BASIC GEAR DATA
11	☐ US Customary units	☒ Single stage ☐ Single helical ☐ Double stage ☒ Double helical ☐ Epicyclic ☐ horizontal offset
12	☒ SI units	
13	☐ RATING REQUIREMENTS	
14	Driven equip. (2.1.4): Norm. _____ Max _____ kW	
15	Driver: Rated _____ Max _____ kW	
16	Normal transmitted power (2.2.2) _____ kW	
17	Gear unit rated power (2.2.1) <u>1620</u> kW	
18	Torque @ max cont speed _____ Nm	
19	Max torque (2.2.1) _____ Nm @ _____ rpm	
20	☐ Reducer ☒ Increaser	
21	Rated speed (2.1.5):	Mechanical rating (1.5.16) <u>2268</u> kW @ <u>1800 / 10737,9</u> rpm
22	Input <u>1800</u> rpm ☐ Specified ☒ Nominal	Gear service factor (2.2.3.1) <u>1,46</u> API 613/2003 5 TH (actual)
23	Output <u>10736</u> rpm ☐ Specified ☒ Nominal	Full load gear unit power loss <u>21</u> kW
24	Allow var in gear ratio (2.1.5) (+) (-) _____ %	Gear Unit Mechanical efficiency <u>98,70</u> %
25	Max continuous speed (1.5) <u>1800 / 10736</u> rpm	Rating speed Pinion <u>10.737,9</u> Gear <u>1.800,0</u> rpm
26	Trip speed (1.5) (2.1.7) <u>1980 / 11809,6</u> rpm	Hardness used for
27	Gear service factor (2.2.3.1) <u>1,4</u> API 613/2003 5 TH (min)	Rating, (HB or Rc) Pinion <u>58 HRC</u> Gear <u>58 HRC</u>
28	Hardness (2.2.3.2) Pinion _____ Gear _____	Tooth pitting index, "K" (2.2.4.1) (2.2.4.2)
29	Shaft assembly designation (2.1.19) <u>L/R</u>	Allowable <u>2,17</u> Actual <u>2,06</u> MPa
30	HS shaft rot fac'g opt'g (2.1.20.2) ☒ CW ☐ CCW	Material index number (Fig 3, Table 4) <u>3,03</u> MPa
31	LS shaft rot fac'g opt'g (2.1.20.2) ☒ CW ☐ CCW	Bending stress number, "S _t " (2.2.5.1) (2.2.5.2)
32	External loads (2.1.16) _____	Pinion: Allowable <u>265,4</u> Actual <u>251,0</u> MPa
33	Other operating conditions (2.2.2) (2.6.1.3) _____	Gear: Allowable <u>265,4</u> Actual <u>238,8</u> MPa
34		Pitch line velocity <u>63,0</u> m/s
35	☐ INSTALLATION DATA (2.1.14)	Anticipated SPL (2.1.6) <u>82</u> dB(A) @ <u>1</u> m
36	☐ Indoor ☐ Heated ☐ Under roof	WR ² referred to LS shaft <u>29,88</u> kgm ²
37	☒ Outdoor ☐ Unheated ☐ Partial sides	Breakaway torque <u>90</u> Nm @ LS Shaft
38	☐ Grade ☐ Mezzanine ☒ ONSHORE	Pinion teeth hardness range <u>58 - 63 HRC</u>
39	☐ Winterization required ☐ Tropicalization required	Pinion teeth hardening method <u>CARBURIZED</u>
40	Electrical area (2.1.10) Class _____ Grp _____ Div _____	☐ HS shaft separate hardness range _____
41	Electrical area (2.1.10) Zone <u>2</u> Grp <u>IIA</u> Temp <u>T1</u> °C	Gear teeth (rim) hardness range <u>58 - 63 HRC</u>
42	Max allow SPL (2.1.6) _____ dB(A) @ _____ m	Gear teeth hardening method <u>CARBURIZED</u>
43	Elevation _____ m Barometer _____ kPa abs	Gear hub:
44	Range of ambient temperatures:	☒ Forged cylinder ☐ Forged & Capped ☐ Fabricated
45	Dry bulb _____ °C Wet bulb _____ °C	Gear to Shaft fit method (2.5.3.2)
46	Normal _____ °C	☐ Integral ☐ Keyed interference ☒ Keyless interference
47	Maximum <u>82</u> °C	Rim attachment (2.5.3.2) <u>FORGED GEAR WHEEL</u>
48	Minimum <u>0</u> °C	LS shaft hardness range <u>HB 230 - 274</u>
49	Unusual conditions ☐ Dust ☐ Fumes	Journal static weight loads (2.6.6.3)
50	☐	Pinion <u>37</u> / <u>4</u> kg Gear <u>347</u> / <u>253</u> kg
		Total gear unit assembled weight <u>1900</u> kg
		NOTES: _____

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

■ GEAR DATA				○ COUPLINGS AND GUARDS		
	Pinion	Gear		Pinion	Gear	
Number of teeth	29	173	Coupling furnished by (3.2.1)	Compr. Supplier	Compr. Supplier	
Gear ratio	5,97		Mount coupling halves (3.2.2)	Compr. Supplier	Compr. Supplier	
Tangential load, *Wt* (2.2.4.2)	25.731	N	Cplg. guard adapter by (3.2.3)	Gear Supplier	Gear Supplier	
AGMA Geometry factor *J*	0,52	0,54	Cplg. guard furnished by (3.2.3)	Compr. Supplier	Compr. Supplier	
Pitch diameter	111,98	668,02	Coupling vendor (3.2.3)			
Outside diameter	120,30	673,50	Vendor's model number (3.2.3)			
Root diameter	103,05	656,32	Coupling weight on shaft, kg	10,4	26,4	
Center groove diameter	93,00	640,00	CG Inboard / outboard of shaft end	Outboard	Outboard	
Normal pressure angle	20,00	deg	Hub drill template provided	☐	☐	
Normal diametral pitch	7,26	in ⁻¹	■ SHAFT END DETAIL (2.5.4.2)			
Helix angle	24,25	deg	Shaft end detail specified by: ☒ Purchaser ☐ Gear vendor			
Center distance	390,00	mm	(Integral unless otherwise specified)			
Backlash min	0,28	mm	Shaft end detail if 'otherwise' specified:			
Net face width, *Fw*	130,00	mm	Pinion Gear			
Pinion L/D	1,74		Tapered / Keyless ☐ ☐ ☐ ☐			
Face overlap ratio	4,86		Tapered / 1-Key ☐ ☐ ☐ ☐			
Transverse contact ratio	1,45		Tapered / 2-Keys ☐ ☐ ☐ ☐			
AGMA 6011 service factor	2,87		Cylindrical / 1-Key ☐ ☐ ☐ ☐			
Rating based on ANSI/AGMA 6011 with SF=1.0			Cylindrical / 2-Keys ☐ ☐ ☐ ☐			
Durability Power	5404	kW	Other ☒ Flanged ☐ ☐ ☐			
Strength Power	4652	kW	Shaft diameter 75,0 120,0 mm			
Tooth Surface Finish, Ra	0,4	µm	(If integral flange use diameter immediately adjacent to flange)			
Tooth Generation Process	Hobbing		■ RADIAL BEARINGS			
Tooth Finishing Process	Grinding		Pinion Gear			
Lead modification (2.2.4.6) ☒ Not Req'd ☐ Req'd			Type T.PADS / T.PADS CYL. / CYL.			
Calculated Total Lead Mismatch		µm	Diameter 80 / 80 120 / 120 mm			
■ SCUFFING DATA (2.2.6)			Length 56 / 56 60 / 60 mm			
Scuffing Data per ANSI/AGMA 925-A03			Journal velocity 45,0 / 45,0 11,3 / 11,3 m/s			
Scuffing Risk (2.2.6) <=5% (Low) Calculation Method AGMA925			Loading 3,08 / 3,10 2,52 / 2,26 N/mm²			
Composite surface roughness, ox	0,57	µm	Clearance (min-max)			
Specific film thickness, EHL Amin	2,54	µm	Span 340 340 mm			
Tooth temperature, θm	80	°C	Power loss each bearing 6,3 / 6,3 0,7 / 0,7 kW			
Maximum contact temperature, θBmax	93	°C	Oil flow each bearing 15,0 / 15,0 5,0 / 5,0 l/min			
■ MATERIALS			■ THRUST BEARINGS			
Gear casing Steel Oil seals aluminium			Location			
Pinion(s) 18CrNiMo7-6			Manufacturer FLENDER FLENDER			
Gear rim(s) 18CrNiMo7-6			Type NO COMB.TAP.LANDS			
HS Shaft Integral LS Shaft 42CrMo4			Size BPK LEG 4"			
Radial bearings Babbit Backing Steel			Area 5160 mm²			
Thrust bearing(s) Babbit Backing Steel			Loading 1,35 MPa			
○ SHAFT END DETAIL			Rating 1,50 MPa			
☒ Gear shaft end for coupling integral flange (2.5.4.2)			Int. thrust load N			
☒ Pinion shaft end for coupling integral flange (2.5.4.2)			Ext. thrust load 2.700 4.250 N			
☒ Other : WITHOUT BOLTS			Power loss each 0,0 5,0 kW			
			Oil flow each bearing 0,0 15,0 l/min			
			NOTES :			

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. **41104** Item No. **B**
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision **1** Date **06.03.2015** By **HNI**

○ LUBRICATION REQUIREMENTS ☐ Oil system furnished by (2.8.3) _____ ☐ Other _____ ☐ Gear vendor _____ ☐ Oil visc. _____ cp @ 40°C _____ cp @ 100°C (2.8.6) ☐ ISO Grade _____ Load stage (2.2.6) 7,0 ■ MESH Mesh and windage power loss 2,0 kW Oil flow, mesh 9,0 l/min ■ LUBRICATION REQUIREMENTS Min. startup oil temperature 20,0 °C Normal oil inlet temperature 60,0 °C Maximum oil inlet temperature 65,0 °C Unit oil flow (total) 64,0 l/min Unit oil pressure 2,5 bar ☐ Oil visc. _____ cp @ 40°C _____ cp @ 100°C (2.8.6) ☐ ISO Grade 46 Load stage (2.2.6) 7,0 ■ PIPING CONNECTIONS <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Service</th> <th>No.</th> <th>Size</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>Lube oil inlet</td> <td>1</td> <td>1,5 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Lube oil outlet</td> <td>1</td> <td>6 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Casing drain *</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Vent</td> <td>1</td> <td>1,5 in.</td> <td>ANSI 150 LBS</td> </tr> <tr> <td>Casing purge</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> * Casing drain is 'dead bottom' housing drain, not lube oil outlet ○ MOUNTING PLATES ☐ Gear furnished with (3.3.1.1) ☐ Baseplate ☐ Soleplate ☐ Subplate(s) (3.3.2.10) ☐ Mounting plates(s) furnished by (3.3.1.1) _____ ☐ Baseplate leveling (3.3.2.3) _____ ☐ Baseplate with leveling pads (3.3.2.3) ☐ Baseplate suitable for column mounting (3.3.2.4) ☐ Vendor review of purchaser's foundation dwgs. (2.1.13) ☐ Grout type (3.3.1.2.4) _____ ○ CONTRACT DATA ☐ Test data prior to shipment _____ ☒ Progress report (5.3.3) _____ ☐ Vendor signoff of inspector checklist (4.1.1.3) ☒ Information retained for 20 years (4.2.1.1) (4.2.2.6.1) ☐ Technical manual (5.3.5.4) ☒ PAINTING (4.4.3.1) ☒ Flender standard RAL5015 (blue) ☒ Painting housing interior not allowed (2.3.1.14) ○ SHIPMENT ☐ Steel rotor storage container (4.4.5) ☐ Shaft covers (4.4.4) <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Contract unit</th> <th>Spares</th> </tr> </thead> <tbody> <tr> <td>Export boxing</td> <td>☐</td> <td>☐</td> </tr> <tr> <td>Domestic boxing</td> <td>☐</td> <td>☐</td> </tr> <tr> <td>Outdoor storage over 6 mos.</td> <td>☐</td> <td>3 years indoor ☐ (4.4.3.9)</td> </tr> </tbody> </table>	Service	No.	Size	Type	Lube oil inlet	1	1,5 in.	ANSI 150 LBS	Lube oil outlet	1	6 in.	ANSI 150 LBS	Casing drain *				Vent	1	1,5 in.	ANSI 150 LBS	Casing purge					Contract unit	Spares	Export boxing	☐	☐	Domestic boxing	☐	☐	Outdoor storage over 6 mos.	☐	3 years indoor ☐ (4.4.3.9)	○ ADDITIONAL REQUIREMENTS ○ VIBRATION DETECTORS RADIAL (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ Total No. 8 ☒ X-Y probes pinion bearings ☒ Coupling end ☒ Blind end ☒ X-Y probes gear bearings ☒ Coupling end ☒ Blind end ☐ Other _____ AXIAL (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ Total No. 2 ☐ Dual probes at each thrust bearing ☐ Single probe any shaft without thrust bearing ☐ Other _____ ONE EVENT PER REVOLUTION PROBE (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA Total No. 2 ☒ One on input shaft ☒ One on output shaft ☐ Other _____ ACCELEROMETER (3.4.2.1) (2.7.4.5) (2.7.4.6) ☒ Manufacturer BENTLY NEVADA ☒ No. required 2 ☒ Pinion coupling end ☒ Gear coupling end ☐ Other _____ ○ TEMPERATURE DETECTORS ☐ Dial type thermometers (3.4.2.7) _____ ☒ Type brg. temp. sensors (3.4.2.7) (2.7.1.3) PT100 ☐ RTD ☐ Thermocouple / ☐ Simplex ☒ Duplex Calibration Yes ☒ HSAS bearings no. sensors each 2 / 2 ☒ Thrust number of sensing elements each face 2 ○ OTHER VIBRATION AND TEMPERATURE <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>(3.4.2.5) (3.4.2.6)</th> <th>Other</th> <th>Gear vendor</th> </tr> </thead> <tbody> <tr> <td>Oscillator demodulator supplied by</td> <td>☐</td> <td>☒</td> </tr> <tr> <td>Vibration monitor supplied by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Vibration shutdown delay time _____ seconds</td> <td></td> <td></td> </tr> <tr> <td>Temperature monitor supplied by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Oscillator demodulator J-box by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>Temp. sensor termination J-box by</td> <td>☒</td> <td>☐</td> </tr> <tr> <td>J-box type _____ Mount _____</td> <td></td> <td></td> </tr> </tbody> </table> ○ MISCELLANEOUS ☒ Undamped critical analysis report (2.6.2.1) ☐ w/ dampd rotr respsn analys rpt (2.6.2.4.3) (2.6.2.6) Torsional analysis by (2.6.5.2) ☐ Gear vendor ☒ Other ☒ Spare set of gear rotors (4.3.2.4) ☐ Gear case furnished with inlet purge connection (2.4.3) ☐ Orientation of oil inlet & drain conns. (2.4.6) _____ ☒ Filter breather location (2.3.1.12) Prev. on upper casing ☐ Torsional device provisions (2.5.4.5) ☐ Rotor vertical storage provisions (2.5.4.8) ☐ Rotor vertical storage fixture(s) (3.6.2) _____ ☐ Vendor service rep. on site (2.1.13)	(3.4.2.5) (3.4.2.6)	Other	Gear vendor	Oscillator demodulator supplied by	☐	☒	Vibration monitor supplied by	☒	☐	Vibration shutdown delay time _____ seconds			Temperature monitor supplied by	☒	☐	Oscillator demodulator J-box by	☒	☐	Temp. sensor termination J-box by	☒	☐	J-box type _____ Mount _____		
Service	No.	Size	Type																																																										
Lube oil inlet	1	1,5 in.	ANSI 150 LBS																																																										
Lube oil outlet	1	6 in.	ANSI 150 LBS																																																										
Casing drain *																																																													
Vent	1	1,5 in.	ANSI 150 LBS																																																										
Casing purge																																																													
	Contract unit	Spares																																																											
Export boxing	☐	☐																																																											
Domestic boxing	☐	☐																																																											
Outdoor storage over 6 mos.	☐	3 years indoor ☐ (4.4.3.9)																																																											
(3.4.2.5) (3.4.2.6)	Other	Gear vendor																																																											
Oscillator demodulator supplied by	☐	☒																																																											
Vibration monitor supplied by	☒	☐																																																											
Vibration shutdown delay time _____ seconds																																																													
Temperature monitor supplied by	☒	☐																																																											
Oscillator demodulator J-box by	☒	☐																																																											
Temp. sensor termination J-box by	☒	☐																																																											
J-box type _____ Mount _____																																																													

SPECIAL PURPOSE GEAR UNITS
API 613 FIFTH EDITION
DATA SHEET SI UNITS

Job No. 41104 Item No. B
P.O. No. _____ Date _____
Requisition No. _____
Inquiry No. _____
Revision 1 Date 06.03.2015 By HNI

O INSPECTIONS AND TESTS (4.1)				
☐ Advance notice of witness testing required (4.1.3)				
Number calendar days _____				
	Req'd	Witness	Observe	Test Log
Shop Inspection (4.1.1)	☐	☐	☐	
Cleanliness Inspection (4.2.3.3)	☐	☐	☐	
Hardness Verification (4.2.3.3)	☒	☐	☐	☒
Dismantle-reassembly (4.3.2.3.1)	☒	☐	☐	☐
Contact Check (2.5.2.2)	☒	☐	☐	☐
Contact Check Tape Lift (2.5.2.2)	☒	☐	☐	☒
Gear accuracy check (2.5.2.1)	☒	☐	☐	☐
Double helical axial stability (2.5.2.3)	☒	☐	☐	☒
Special testing integral forged gears (2.5.3.3)				
(testing per mutual agreement)	☐	☐	☐	☐
Residual unbalance check (2.6.6.2)	☒	☐	☐	☒
Mechanical Run Test (Main) (4.3.2)	☒	☐	☐	☒
Mechanical Run Test (Spare) (4.3.2.4)	☐	☐	☐	☐
Addl. Mechanical Tests (4.3.2.2.16)	☐	☐	☐	☐
Part or Full Load And Full Speed				
Test (4.3.3.1)	☐	☐	☐	☐
Full torque, reduced speed (4.3.3.2)	☐	☐	☐	☐
Full Torque Static Test (4.3.3.3)	☐	☐	☐	☐
Back-To-Back Locked Torque				
Test (4.3.3.4)	☐	☐	☐	☐
Sound Level Test (4.3.3.5)	☒	☐	☐	☒
Additional gear tooth test (4.2.2.8)	☐	☐	☐	☐
Use shop Lube System	☒	☐	☐	
Use job lube system	☐	☐	☐	
Use shop Vibration Probes, Etc.	☐	☐	☐	
Use job Vibration Probes, Etc.	☒	☐	☐	
Final Assembly, Maintenance &				
Running Clearance (4.2.1.1.e)	☒	☐	☐	☒
Oil System Cleanliness (4.2.3.2)	☐	☐	☐	
Oil System-Casing Joint				
Tightness (4.3.2.1.4)	☐	☐	☐	
Warning And Protection				
Devices (4.3.2.1.5)	☐	☐	☐	
Seismic Vibration Data (4.3.2.2.3)	☐	☐	☐	☐
Vibration, Phase Plots (4.3.2.2.12)	☒	☐	☐	☒
Oil Inlet Range test (4.3.2.2.13)	☐	☐	☐	☐
Tape recorded Vibration Data	☒	☐	☐	☒
(4.3.2.2.14) (4.3.2.2.15)	☐	Purchaser copy		
NON-DESTRUCTIVE TESTING (4.2.1.2) (4.2.2.1)				
	Surface	Sub surface		Log
☐ Casing	☐	☐		☐
☒ Rot. Elmts.	☒	☒		☒
☒ Bearings	☒	☒		☒
☐ Other :	☐	☐		☐
(Specify)				



NOTES : _____

During start-up, gears can exhibit a transient spike reading of vibration levels that will exceed shutdown settings. Therefore a trip multiplier is recommended in the control system.

Mechanical running test duration 4 hours including

- Shaft vibration record using job vibration probes if ordered
- Bearings temperature records
- Casing vibration measurement
- Sound level pressure measurement
- Power losses measurement at oil outlet
- Performed with oil ISO VG 32

Oil flow requirement and power losses are calculated values only, add normal safety margins for sizing heat exchangers.



ADDITIONAL TECHNICAL DATASHEET				Job No. <u>41104</u> Item No. <u>B</u> P.O. No. _____ Date _____ Requisition No. _____ Inquiry No. _____ Revision <u>1</u> Date <u>06.03.2015</u> By <u>HNI</u>																																																																											
☒ ADDITIONAL GEAR DATA				☐ TURNING GEAR (Dimensioning is preliminary !)																																																																											
<i>Efficiency</i>				<i>Calculation results</i>																																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Percent of rated power</th> <th style="width: 50%;">Efficiency</th> </tr> </thead> <tbody> <tr> <td>100%</td> <td style="text-align: center;">98,70</td> </tr> <tr> <td>75%</td> <td style="text-align: center;">98,56</td> </tr> <tr> <td>50%</td> <td style="text-align: center;">98,38</td> </tr> <tr> <td>25%</td> <td style="text-align: center;">97,42</td> </tr> <tr> <td>10%</td> <td style="text-align: center;">87,68</td> </tr> </tbody> </table>				Percent of rated power	Efficiency	100%	98,70	75%	98,56	50%	98,38	25%	97,42	10%	87,68	Required turning speed _____ rpm Actual turning speed _____ rpm Required breakaway torque _____ Nm Actual breakaway torque _____ Nm Actual maximum torque _____ Nm Actual acceleration time _____ s																																																															
Percent of rated power	Efficiency																																																																														
100%	98,70																																																																														
75%	98,56																																																																														
50%	98,38																																																																														
25%	97,42																																																																														
10%	87,68																																																																														
<i>Losses</i>				<i>Motor</i>																																																																											
Power loss at no load _____ kW Heat rejection _____ kcal/h				Supplier _____ Power _____ kW Voltage _____ V Frequency _____ Hz Speed _____ rpm Electric standard _____																																																																											
☐ PUMP DETAILS (Dimensioning is preliminary !)				<i>Turning gear</i>																																																																											
Design : _____ Speed : _____ rpm Oil flow : _____ l/min Oil pressure : _____ bar NPSH : _____ m Safety valve : _____ Driving method : _____ Material : _____ Flanges : _____ Testing : _____ Furniture of ATEX certificate : _____				Type _____ Ratio _____																																																																											
				<i>Clutch</i>																																																																											
				Type _____ Max allowable torque _____ Nm																																																																											
				<i>Miscellaneous</i>																																																																											
				Starting device _____ Switch details _____																																																																											
☒ INSTRUMENTATION PACKAGE																																																																															
<i>Thermometer</i>				<i>Thermoelements</i>																																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Bearing</th> <th>Thrust bearing</th> <th>Oil inlet/outlet</th> </tr> </thead> <tbody> <tr> <td>Qty</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Type</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					Bearing	Thrust bearing	Oil inlet/outlet	Qty				Type				<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Bearing</th> <th>Thrust bearing</th> <th>Oil inlet/outlet</th> </tr> </thead> <tbody> <tr> <td>Type</td> <td>DUPLEX 2x3F</td> <td>DUPLEX 2x3F</td> <td></td> </tr> <tr> <td>Classification</td> <td>IEC60751</td> <td>IEC60751</td> <td></td> </tr> <tr> <td>Removable from the outside</td> <td>NO</td> <td>NO</td> <td></td> </tr> <tr> <td>ATEX</td> <td>ATEX Eexia</td> <td>ATEX Eexia</td> <td></td> </tr> </tbody> </table>					Bearing	Thrust bearing	Oil inlet/outlet	Type	DUPLEX 2x3F	DUPLEX 2x3F		Classification	IEC60751	IEC60751		Removable from the outside	NO	NO		ATEX	ATEX Eexia	ATEX Eexia																																									
	Bearing	Thrust bearing	Oil inlet/outlet																																																																												
Qty																																																																															
Type																																																																															
	Bearing	Thrust bearing	Oil inlet/outlet																																																																												
Type	DUPLEX 2x3F	DUPLEX 2x3F																																																																													
Classification	IEC60751	IEC60751																																																																													
Removable from the outside	NO	NO																																																																													
ATEX	ATEX Eexia	ATEX Eexia																																																																													
<i>Shaft vibrations</i>																																																																															
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Radial</th> <th colspan="2">Axial</th> <th>Keyphasor</th> <th>Accelerometer</th> </tr> </thead> <tbody> <tr> <td>Type</td> <td>B.N. 3300 XL 8mm Sys. 9M</td> <td>HS</td> <td>No</td> <td>B.N. 3300 XL 8mm Sys. 9M</td> <td>ACCELEROMETER BENTLY</td> </tr> <tr> <td></td> <td></td> <td>LS</td> <td>BENTLY NEVADA 3300 XL 8mm Sys. 9M</td> <td></td> <td></td> </tr> <tr> <td>Probe</td> <td>Yes</td> <td>HS</td> <td>No</td> <td>Yes</td> <td></td> </tr> <tr> <td></td> <td></td> <td>LS</td> <td>Yes</td> <td></td> <td></td> </tr> <tr> <td>Proximitior</td> <td>Yes</td> <td>HS</td> <td>No</td> <td>Yes</td> <td></td> </tr> <tr> <td></td> <td></td> <td>LS</td> <td>Yes</td> <td></td> <td></td> </tr> <tr> <td>Probe holder</td> <td>Yes</td> <td>HS</td> <td>No</td> <td>Yes</td> <td></td> </tr> <tr> <td></td> <td></td> <td>LS</td> <td>Yes</td> <td></td> <td></td> </tr> <tr> <td>Connection head</td> <td>Yes</td> <td>HS</td> <td>No</td> <td>Yes</td> <td></td> </tr> <tr> <td></td> <td></td> <td>LS</td> <td>Yes</td> <td></td> <td></td> </tr> <tr> <td>mounting kit</td> <td></td> <td></td> <td></td> <td></td> <td>Yes</td> </tr> </tbody> </table>									Radial	Axial		Keyphasor	Accelerometer	Type	B.N. 3300 XL 8mm Sys. 9M	HS	No	B.N. 3300 XL 8mm Sys. 9M	ACCELEROMETER BENTLY			LS	BENTLY NEVADA 3300 XL 8mm Sys. 9M			Probe	Yes	HS	No	Yes				LS	Yes			Proximitior	Yes	HS	No	Yes				LS	Yes			Probe holder	Yes	HS	No	Yes				LS	Yes			Connection head	Yes	HS	No	Yes				LS	Yes			mounting kit					Yes
	Radial	Axial		Keyphasor	Accelerometer																																																																										
Type	B.N. 3300 XL 8mm Sys. 9M	HS	No	B.N. 3300 XL 8mm Sys. 9M	ACCELEROMETER BENTLY																																																																										
		LS	BENTLY NEVADA 3300 XL 8mm Sys. 9M																																																																												
Probe	Yes	HS	No	Yes																																																																											
		LS	Yes																																																																												
Proximitior	Yes	HS	No	Yes																																																																											
		LS	Yes																																																																												
Probe holder	Yes	HS	No	Yes																																																																											
		LS	Yes																																																																												
Connection head	Yes	HS	No	Yes																																																																											
		LS	Yes																																																																												
mounting kit					Yes																																																																										
<i>Junction box(es)</i>				<i>Miscellaneous</i>																																																																											
Qty <u>0</u> Manufacturer _____ Material _____ ATEX <u>None</u>				Identification ☒ wire ☒ conduit ☐ junction box Conduit type _____ Transmitter type _____ Qty _____ Terminal block type _____ Qty _____																																																																											

Commercial Conditions

- Prices are quoted FCA Illkirch-Graffenstaden following Incoterms 2010 including packing cat 1A of SEI, 1999 issue, ind. 2.
- Progress payments : 100% at delivery.
- This quotation is subjected to the Flender Graffenstaden Standard Terms and Conditions of Sales and valid for acceptance until the 15th of July 2015.
- Where approval of drawings is required, approval must be in line with the document schedule.
- Warranty period is 18 months of operation or 24 months after delivery whichever occurs first. We recommend the supervision of our engineer for the commissioning.
- Flender-Graffenstaden SAS shall not be obligated to fulfill this agreement if such fulfillment is prevented by any impediments arising out of national or international foreign trade or customs requirements or any embargoes or other sanctions.


Applicable documents for the quotation (available on demands)

Documents schedule,
Quality plan
Painting standard,
Standard Terms and Conditions of Sales

We thank you for the opportunity of quoting and look forward to the pleasure of serving you.

Very truly yours,

N. HOST
(Project Engineer)



Y. FRIEDMANN
(Sales Manager)



Generated with CAMEC V 4.9.5 26 Feb 2014

**** "This quotation is subject to confidentiality. Information thereof may not be shared with or forwarded to any third parties!"**